



LL-301 WIRING DIAGRAM

ELECTRICAL WARNINGS

CAUTION! HIGH VOLTAGE. Disconnect Power before Installing or Servicing.

Failure to follow these warnings could cause injury or death, damage the LL-301, and/or void the warranty.

- Read and understand the LL-301 installation instructions and safety labels before you begin your installation.
- Turn off the power before installing or servicing the LL-301.
- Follow all national and local electrical and construction codes and regulations.
- Avoid all temptation to disassemble the LL-301 because there are no serviceable parts and tampering with it could cause shock.
- Comply with the maximum voltage rating of the LL-301 as specified. i2Systems is not liable for damage due to miswiring of low voltage signal wires to line voltage or any voltage higher than their maximum rating.
- Use the LL-301 only with i2Systems LED Lighting Products marked as LightLink Compatible.
- Use wire rated for +105°C or higher.

HAVE QUESTIONS? CALL US BEFORE YOU START!

i2Systems Technical Support is available from 8 a.m. to 5 p.m. EST by phone **1.860.567.0708** or email at support@i2systems.com